

J. S. CULLINAN  
HOUSTON, TEXAS

MEMORANDUM

February 19, 1931.

HOUSTON NEGRO HOSPITAL  
Elevations

Mr. Maurice J. Sullivan,  
Second National Bank Bldg.,  
Houston, Texas.

Dear Sir:

In viewing the print of the grounds just submitted by Mr. Bringhurst, I note the following:

Main Building	57.1
School of Nursing	56.05
Utility Building	53.6

As this print shows sidewalk elevation at southwest corner at 52.6, I am wondering if the floor level of the Utility Building is not too low and if it would not be better to raise such by filling to 53.5, or at least to 53.0, to take care of a possible flood, that section of the City as we know being comparatively flat and as we further know, water covering the floor of the Utility Building would not only be very objectionable but might cause considerable damage and annoyance.

Please give this your consideration before the work proceeds, advising Mr. Bringhurst of your conclusions.

Yours very truly,

J. S. CULLINAN.

JSC-CZ

cc-Mr. J. H. Bringhurst.

Ho