

SOUTHWESTERN LABORATORIES

928 1-2 MONROE STREET
FORT WORTH, TEXAS

215 1-2 MAIN STREET
HOUSTON, TEXAS

1812 1-2 MAIN STREET
DALLAS, TEXAS

Dallas

3/4/26

Texas,

192

To Mr. Don Hall,
Houston, Texas.

107 Bbls. Trinity Brand Cement has been sampled by us at Dallas

for use in construction of Negro Hospital

Date Sampled 2/26/26 Initial G.P. Web Car No. 75717

Boiling Test O.K. Fineness 18.6 % Retained on 200 Mesh Screen

Initial Set 3:00 Final Set 4:50 S. W. L. Seal Nos. 13743-4

THIS CEMENT HAS PASSED THE ONE DAY TESTS.
REPORTS WILL BE SENT YOU WHEN SEVEN AND 28 DAY TESTS ARE COMPLETED.