



# THE ARLINGTON HOTEL

D. F. GAINES, PRESIDENT  
W. E. CHESTER, VICE PRES. & GEN. MGR.

HOT SPRINGS NATIONAL PARK  
ARKANSAS

FIRE PROOF - 500 GUEST ROOMS  
EVERY ROOM WITH BATH OR TOILET

Memo

Jan 23 192  
No 244 HS

H. K. Hospital  
Water System

WTS

Copy of Mr Wooding letter  
2<sup>nd</sup> and print received

It was not contemplated  
that this be a sprinkling  
system but line, hydrants,  
and hose -

It should include the north  
as well as south end of  
property in order to  
permit reaching all  
hedge, shrubbery and lawn  
The lot being 250 wide  
the water lines would  
center at 62 1/2 feet



# THE ARLINGTON HOTEL

D. F. GAINES, PRESIDENT  
W. E. CHESTER, VICE PRES. & GEN. MGR.

HOT SPRINGS NATIONAL PARK  
ARKANSAS

FIRE PROOF - 500 GUEST ROOMS  
EVERY ROOM WITH BATH OR TOILET

192

from property lines — though  
wide enough to clear the  
building at the north end  
then contract to 62' —  
The P A P Co may have some  
good 2<sup>d</sup> hand two inch that  
could be purchased as  
cheaply as 1 1/4 and if properly  
wrapped or asphalted would  
last longer than butt weld  
1 1/4 inch — if not the latter  
may be used —  
hydrants should near corners  
at south end line at  
suitable points around  
building and say every  
3<sup>d</sup> point on the N & S  
lines



# THE ARLINGTON HOTEL

D. F. GAINES, PRESIDENT  
W. E. CHESTER, VICE PRES. & GEN. MGR.

HOT SPRINGS NATIONAL PARK  
ARKANSAS

FIRE PROOF - 500 GUEST ROOMS  
EVERY ROOM WITH BATH OR TOILET

3

192

The latter should tap main  
line north of building  
and not building supply  
line

all pipe should be of  
one size 2" - 1 1/2" or 1 1/4"  
when plan revised  
ass. C & C or Mullin to  
look it over <sup>both estimates</sup> for <sup>on the ground</sup>  
suggested changes they  
thrice should be made  
or savings effected,  
following which the work  
may proceed -  
the line should be  
laid to grade conforming  
with street levels regardless



# THE ARLINGTON HOTEL

D. F. GAINES, PRESIDENT  
W. E. CHESTER, VICE PRES. & GEN. MGR.

HOT SPRINGS NATIONAL PARK  
ARKANSAS

4

FIRE PROOF - 500 GUEST ROOMS  
EVERY ROOM WITH BATH OR TOILET

192

of present surface level.  
Cut off valves should be  
placed where each line  
taps the city service line  
or meter, if the latter is required  
I am returning the print  
herewith. Revision should  
be made on one of  
the new prints showing  
location of trass

JSC

MEMORANDUM

Hot Springs National Park, Arkansas,  
January 23, 1928.

HOUSTON NEGRO HOSPITAL  
Water System

W. T. Sinclair, Secretary,  
20th Floor,  
Petroleum Building,  
Houston, Texas.

Copy of Mr. Wooding's letter 20th and print received.  
It was not contemplated that this be a sprinkling system, but  
line, hydrants, and hose.

It should include the north as well as south end of  
property in order to permit reaching all hedge, shrubbery and  
lawn. The lot being 250 feet wide, the water lines would center  
at 62 1/2 feet from property lines, though wide enough to clear  
the building at the north end, then contract to 62 1/2.

The P.S.P.Co. may have some good 2nd-hand two inch  
that could be purchased as cheaply as 1 1/4, and if properly wrapped  
or asphalted, would last longer than butt weld 1 1/4 inch - if not,  
the latter may be used.

Hydrants should near corners at south end line, at  
suitable points around building, and say every third joint on the  
N & S lines. The latter should tap main line north of building  
and not building supply line.

All pipe should be of one size, 2", 1 1/2 or 1 1/4.

When plans revised, ask CFC or Mullin to look it over  
(both estimates and on the ground) for any suggested changes they  
think should be made, or savings effected, following which the  
work may proceed.

The line should be laid to grade conforming with  
street levels regardless of present surface level. Cut-off valves  
should be placed where each line taps the city service line or  
meter, if the latter is required.

I am returning the print herewith. Revision should be  
made on one of the new prints showing location of trees.

J. S. CULLINAN

JSC-CZ

Ho-NY-HS