

THIS CEMENT HAS **Yes** PASSED THE ONE DAY TESTS

SOUTHWESTERN LABORATORIES

828 1-2 Monroe Street
Ft. Worth, Texas

215 1-2 Main Street
Houston, Texas

1812 1-2 Main Street
Dallas, Texas

Job No. **M657 H** Houston, Texas, **Apr. 2, 1926** 192.....

To **Don Hall, Constructor,**
Houston.

187½ Bbbls **Trinity** Brand Cement has been sampled by us at **THE JOB**

for use in construction of **Negro Hospital**

Date Sampled **Apr 1** Initial **CC&STL** Car No. **57637**

Boiling Test **OK. 5** hrs. Fineness **14.4** per cent Retained on 200 Mesh Screen

Initial Set **3** hrs. **45** min. Final Set **5** hrs. **25** min. Seal Nos. **none**

THIS IS A ONE DAY REPORT. Per. **H. B. Clay**
REPORTS IN FULL WILL BE SENT YOU WHEN TESTS ARE COMPLETED